


SANITARY CONDITION CERTIFICATE

No. 79/2020

Date.. 27/11/2020

This is to certify that the sanitary condition made by
Sri. The Director Holy Innocents public
school, Kallumalakunnu, Vennicode.
Building No. CP. XIV - 187, 187 B
for School is satisfactory.

This certificate is issued to produce before the secretary, ~~Vennicode~~ ^{Cherunniyoor}
Grama Panchayat, to issue the license for School



Health Inspector


PHC Cherunniyoor

NB: 1. It may be cancelled at any time, if sanitary condition is not satisfactory.

Prepared by S. S. Shize.

Inspected by Benu.

Checked by



MANAGER
Holy Innocents Public School
Kallumalakunnu
Vennicode P.O. Varkala
Pin - 695 318



The Principal
Holy Innocents Public School
Kallumalakunnu
Vennicode P.O. 695 318

KERALA WATER AUTHORITY
QUALITY CONTROL REGIONAL LABORATORY
THIRUVANANTHAPURAM
 Phone No. 0471 2735303

REPORT ON ANALYSIS OF WATER

Name: Holy Innocents Public School, Kallumalakunnu, Mel- Vettoor.
 Date of Receipt: 24/09/2020
 Date of Testing: 24/09/2020

Sl. No.	Characteristics	Units	Desirable limits as per IS 10500 – 2012 (Drinking Water)	Actual Contents
1	Colour	Hazen /Pt.Co.Units	5	5
2	Turbidity (NTU)	NTU	1	0.30
3	pH		6.5-8.5	5.59
4	Electrical Conductivity	us/cm		111.9
5	Temperature	0C		29.0
6	Acidity	mg/litre		12
7	Alkalinity	mg/litre	200	10
8	Sulphate (as SO4)	mg/litre	200	1.6
9	Total dissolved solids	mg/litre	500	55.7
10	Total hardness (as CaCO3)	mg/litre	200	10
11	Calcium (Ca)	mg/litre	75	3.2
12	Magnesium (Mg)	mg/litre	30	0.486
13	Chloride (as Cl)	mg/litre	250	26
14	Fluoride (as F)	mg/litre	1	0.215
15	Iron (as Fe)	mg/litre	1	0.026
16	Nitrate	mg/litre	45	3.593
17	Residual Chlorine	mg/litre	0.2	Nil


Signature of Chemist 


BACTERIOLOGICAL ANALYSIS		
Source	MPN of Coliforms in 100 ml	MPN of E.coli
Borewell	0	0

Remarks:- Sample not collected by this office.


MANAGER
 Holy Innocents Public School
 Kallumalakunnu
 Vennicod P.O. Varkala
 Pin - 695 318




 Signature of Asst.Engineer


The Principal Lab.
 Holy Innocents Public School
 Kallumalakunnu
 Vennicod P.O. 695 318